



# Binghamton-Johnson City JOINT SEWAGE BOARD



Chris Papastrat  
John Paddock (JP)  
Ronald Lake

08/14/2025

George Kolba, Jr.  
Stephen Andrew  
Bruce King

Attn: Mr. James Cummings P.E.  
Hunt EAS  
143 Court Street  
Binghamton NY 13901

*certified*

# 7014 2870 0001 0468 6954

The Joint Sewage Board is requesting that Hunt EAS provide the information below as soon as possible.

- SWPS-4 Pump Starting Elevation
- Maintenance Plan for the flood wall
- Operational/Maintenance Plan for the flood wall, A wet weather operating plan was provided but is not what is needed.

8. Interior Drainage (continued)		
i. Will pumping plants be used for interior drainage? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
If Yes, include the number of pumping plants: <u>SWPS- 4</u> For each pumping plant, list:		
	Plant #1	Plant #2
The number of pumps	2	
The ponding storage capacity	1.4 acres	
The maximum pumping rate	2546 gallons/minute	
The maximum pumping head	19.7 feet TDH (design point)	
The pumping starting elevation		
The pumping stopping elevation	Elevation 836.5	
Is the discharge facility protected?	Existing storm sewer on Old Vestal Road	
Is there a flood warning plan?	Wet Weather Operating Plan 6 1 2025	
How much time is available between warning and flooding?	Time for Vestal River Gauge from 18 to 26 ft.	
Will the operation be automatic? <input checked="" type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
If the pumps are electric; are there backup power sources? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		

Very Truly yours,

*George Kolba Jr*

George Kolba, Jr.  
Chairman

Binghamton-Johnson City Joint Sewage Treatment Facilities  
4480 Vestal Road, Vestal, New York 13850  
Phone: 607-729-2975 Fax: 607-729-3041  
Email: bjcwwtp@stny.rr.com