## December Superintendents Report

January 14, 2024

A correction to the Precipitation for the year 2024 needs to be made. The number (47.77) given last month was the 12 Month Rolling Total. The total for January through November should have been 41.92 MGD.

December 11, 2024, we received a text from Kurt Brown asking if we were taking max, I answered 59.72 MGD and sent another explaining 46.6 MGD from Bing and 14.58 from JC. At the time of the CSO events we were pumping 60+ MGD.

On December 12, 2024, Ron Lake, Josh Holland, Kurt Brown, Ron Warwick, Adam Afify and I had a Teams meeting where we compared all three entities flow data and time stamps. All three systems reported the same data. Please note, this rain event started very slowly and gradually picked up. Compared to many of our rain events that happen as a downpour.

In December we received 3.15 inches of precipitation, for a total of 45.07 inches this year.

The Average flow was 17.47 MGD with a total of 541.50 million gallons.

CBOD = 5 mg/L, 97% removal, TSS = 3 mg/L, 98% removal, Fecals 6 MPN, Ammonia = 0.178 mg/L, 98% Conversion and Phos = 0.19 mg/L, 96% removal, TN = 2.6 mg/L for 86% removal.

In 2024 we removed the following from our influent: 8,673,920 Lbs of TSS, 8,053,897 Lbs of CBOD, 769,064 Lbs of TN, and 158,330 Lbs of Phosphorus.

Micro-Turbines produced 92,143 KWH in December, up from 88,576 KWH in November. Total Miro-Turbine electric production for 2024 was 958,907 KWH.

Solar produced 1967 KWH in December down from 3588 KWH in November. The total production of electricity from Solar for 2024 was 68,973 KWH. This represents 6,949 KWH more than the annual estimate by the vendor.

After 5 years of service, the Solar array has produced approximately 20% of the initial cost of the Solar Cells. The cost of electricity going up will only decrease the payback time.

The year 2024 saw Mechanics perform 5,834 Preventive maintenance tasks utilizing the CMMS software. They removed Main pump number 4 for rebuild. Removed, inspected, and replaced oil in 4 Secondary Influent Pumps (SIPS). Removed and replaced with an upgraded Archimedes screw the North Grit conveyor. Removed and replaced the Backwash Spray water pump Check Valve. Brought in PW Tech (The Manufacturer) to re-furbish and upgrade both Mechanical thickeners. Replaced damaged entries to Gravity thickeners. Completed all buildings Roof inspections and repairs. Installed a flagpole, in conjunction with operators, drained cleaned and had both methanol tanks inspected, All Chemical Bilk storage tanks, and our Petroleum Bulk storage tank inspected.

This year the Operations department has drained, cleaned, and inspected all Primary tanks, CN Cells and DN Cells. Resolved a digester feed sludge Magmeter issue, worked with mechanics to Drain and Clean Ferric and Methanol tanks, Senior Operator tested and became an "A/B" Operator and provided training for all in his department to become PBS "C" operators with an eye to provide training for all employees that go into the field to become "C" operators. The department has met every single Parameter of the SPDES permit for the 28 continuous months since the CN Viewport issue recovery. They continue to refine chemical use through Jar-Testing, process sampling, and optimizing dosing setpoints ultimately reduces our chemical budget. Operations Department has been forming relationships with City, Town, and Village Public works departments to foster collaboration and collection system efficiency as seen in discovering the source of a colored influent sample. Continued training and creating an environment of personal growth and advancement at the facility to ensure a more skilled and capable team for future operational success.

The electrical/instrumentation department completed just over 800 Preventive maintenance tasks utilizing the CMMS program. They worked with Matco to provide them with the appropriate 4800 volt switching operations to enable maintenance of the Breakers for Headhouse and LVS 4 gear which feed the Digester complex. They wired in numerous receptacles throughout the plant to enhance functionality and safety. Added momentary push buttons to the Scum Pit control panels. Wired in a ground for the rebuilt Plant water pumps, uncovered a construction damaged Fiber Optic cable, wired in a new Air conditioning Unit in Building 10, maintained the ChemScan units and UV system, and calibrated/Bump tested gas monitors and instrumentation throughout the facility. They received refresher training with PowerFlo Technologies, ChemScan, WesTech and Wedecco.

We had zero lost work time due to injuries this year, Safety officer provided 18 required training classes and retention of all safety related records, Safety officer continues to work with all departments to create a safe work environment, Started a Hepatitis vaccination program.

Management called in PESH to look at our confined space entries and ensure they align with PESH guidelines.

We had an EPA IWPP audit this year and told us we were one of the better run IWPP programs in the State. We eventually had a closing conference with the EPA on 12/17/2024 and await their conclusion and recommendations.

This year saw the 5-Year plan adopted by the board. This report will evolve through the years to accurately inform the owners of the needs and goals of the facility to run efficiently and cost effectively.

		<u> </u>							Super	intenden	ts Sumi	nary Repo	ort for	2024		<u> </u>							
	FLOW	Precip	CBOD5 RE		REM	REM Tot Susp Solids		REM	Settleab	le Solids	REM	Total Nitrogen		REM	Phosp	horous	REM	Ammonia		REM	TKN		REM
	MGD	Inches	In	out	%	In	out	%	In	out	%	In	out	%	In	out	%	In	out		In	out	
	AVG			limit			limit			limit			limit			limit			limit			limit	
		18 mg/L			20 m	20 mg/L		0.3 mL/L			6.0 mg/L			1.0	1.0 mg/L		1800 I	bs./Day		11000 lbs/Da		└───┤	
Jan	26.40	4.71	116	10	91%	123	5	96%	7.40	0.10	99%	12.9	3.6	72%	2.40	0.340	86%	7.3	0.14	98%	12.3	1.2	90%
Feb	18.72	1.63	181	8	96%	194	3	98%	11.10	0.10	99%	17.8	3.9	78%	3.80	0.290	92%	12.9	0.14	99%	17.7	1.5	92%
Mar	24.33	4.10	137	7	95%	153	4	97%	7.70	0.10	99%	14.2	4.8	66%	2.64	0.358	86%	9.0	0.15	98%	13.7	1.4	90%
Apr	22.87	4.42	150	8	95%	170	5	97%	9.80	0.10	99%	14.9	4.4	70%	3.19	0.459	86%	9.5	0.20	98%	14.6	1.3	91%
May	16.12	3.67	175	7	96%	176	4	98%	13.00	0.10	99%	20.4	4.0	80%	3.10	0.421	86%	10.7	0.15	99%	20.3	1.3	94%
Jun	12.56	3.09	193	10	95%	193	7	96%	16.30	0.10	99%	25.6	2.0	92%	4.02	0.564	86%	12.7	0.33	97%	25.6	1.6	94%
Jul	13.79	6.02	178	9	95%	194	6	97%	14.90	0.10	99%	21.4	2.3	89%	3.74	0.480	87%	12.2	0.20	98%	21.3	1.4	93%
Aug	18.35	7.14	169	6	96%	189	4	98%	12.50	0.10	99%	18.2	3.2	82%	3.57	0.290	92%	10.7	0.16	98%	18.1	1.1	94%
Sep	11.16	1.94	228	5	98%	213	3	99%	15.50	0.10	99%	27.8	3.8	86%	4.63	0.480	90%	16.2	0.17	99%	27.7	1.4	95%
Oct	9.49	1.53	272	5	98%	252	4	98%	17.20	0.10	99%	34.1	2.2	94%	5.37	0.750	86%	18.9	0.29	98%	34.0	1.5	96%
Nov	12.26	3.67	253	4	98%	236	3	99%	14.90	0.10	99%	30.0	3.3	89%	6.30	0.471	93%	17.1	0.35	98%	29.9	1.3	96%
Dec	17.47	3.15	155	5	97%	158	3	98%	10.50	0.10	99%	18.2	2.6	86%	4.59	0.190	96%	11.3	0.18	98%	17.9	0.9	95%
		TOT																					
Avg	16.96	45.07	184	7	96%	188	4.3	98%	12.57	0.10	99%	21.3	3.3	82%	3.95	0.424	89%	12.4	0.21	98%	21.1	1.3	93%
					Α	mmonia l	imit eq	uates t	o approx 6					-		g/L Month	nly Avg.						
										0,		O1A REM											
				Th	e Perm	it for TN =			lonthly Av	-							g 12 Mo	onth Av	g.				
							Outfa	001	includes F		-	-	-	-	N Cell Byp	ass)							
									inese	numpers	repres	ent Outfa	ii trom	001									

## Landfill 2024 Summary

Date	Digested	Lime Stab	Solids Total		Bar screen	Grit and Screen		Grease
	Tons	Tons	Tons	Cost	Tons	Tons	Cost	Tons
January	717.02		717.02	\$28,680.80		22.98	\$1,034.10	
February	613.29		613.29	\$24,531.60		17.01	\$765.45	
March	666.43		666.43	\$26,657.20		29.68	\$1,335.60	
April	685.81		685.81	\$27,432.40		23.46	\$1,055.70	
May	627.24		627.24	\$25,089.60		29.70	\$1,336.50	
June	623.85		623.85	\$25,035.20		22.74	\$1,023.30	
July	768.65		768.65	\$30,746.00		34.95	\$1,572.75	
August	812.06		812.06	\$32,482.40		26.29	\$1,183.05	
September	577.48		577.48	\$23,099.00		19.41	\$873.45	
October	779.48		779.48	\$31,179.90		23.54	\$1,059.30	
November	779.97		779.97	\$31,198.80		19.71	\$886.95	
December	745.87		745.87	\$29,834.80		28.80	\$1,297.80	
Average	699.76		699.76	\$27,997.31		24.86	\$1,118.66	
Sub Total	8,397.15		8,397.15	\$335,967.70		298.27	\$13,423.95	
				\$40/Ton			\$45/Ton	
				\$349,391.65				
				Annual Cost to Da	ite			
		\$4	20,000 budgeted	for 2024 / \$70,	608.35 Under B	udget		
			-	ES8130.54804		-		













			2024 Plan	t Mercury	1									
	Result	Result	Result	Result	Result	Result								
Date	Bing INF Mercury	Bing INF Mercury	JC INF Mercury	JC INF Mercury	Effluent Mercury	Effluent Mercury	Rep Limit							
Date	ng/L	ng/L Blank	ng/L	ng/L Blank	ng/L	ng/L Blank	ng/L							
			lig/L	IIg/L DIdIIK	lig/L	lig/ L Didlik	ng/ L							
January	16.800	<0.208	26.600	<0.208	0.397	<0.208	0.500							
February	14.500	<0.208	26.100	<0.208	1.360	<0.208	0.500							
March	167.000	<0.208	19.400	<0.208	1.000	<0.208	0.500							
April	<0.208	13.500	42.000	<0.208	0.884	<0.208	0.500							
May	10.700	<0.208	19.000	<0.208	0.922	<0.208	0.500							
June	3.500	<0.208	5.550	<0.208	0.773	<0.208	0.500							
July	15.600	0.323	1.230	<0.208	0.855	<0.208	0.500							
August	10.700	0.269	9.160	<0.208	1.410	0.259	0.500							
September	5.060	<0.208	30.200	<0.208	<0.208	0.619	0.500							
October	1.110	<0.208	10.500	<0.208	0.798	<0.208	0.500							
November	19.900	<0.208	14.900	<0.208	0.506	<0.208	0.500							
December	23.800	<0.208	22.300	<0.208	0.479	<0.208	0.500							
Avg in ng/L	26.243		18.912		0.853		0.500							
	Effluent Limit = Daily Max 50ng/L and 12 Month Rolling AVG = 24ng/L													
	Method: EPA 1631E													
	Metals testing performed by Microbac Laboratories													
	Inquired of Microbac for April mercury, they state the numbers are correct													
	_													

	2024 Digester Filter	Cake Mercury Results	
Date	mg/kg	Rep Limit	
January	<0.905	0.905	mg/kg
February	<0.876	0.876	mg/kg
March	<0.872	0.872	mg/kg
April	<0.880	0.880	mg/kg
May	<4.400	4.400	mg/kg
June	<0.929	0.929	mg/kg
July	<0.996	0.996	mg/kg
August	<1.750	1.750	mg/kg
September	<0.935	0.935	mg/kg
October	<0.990	0.990	mg/kg
November	<0.990	0.990	mg/kg
December	<0.984	0.984	mg/kg
Average		1.292	mg/kg
	EPA Metho	od 7471B Dry	
N	Aetals testing performed	by: Microbac Laboratories	

January February March April May June July	Total   Flow   13.92   21.10   26.27   31.81   15.61	LBS TSS IN 752317 933179 979502	LBS TSS OUT 22879 107443	% Removal 97%	LBS CBOD IN	LBS CBOD OUT	% Removal	LBS TKN IN	LBS	%	the River LBS	LBS	1	LBS	LBS	%	LBS	LBS	%	LBS	LBS	%
January February March April May June July	13.9221.1026.2731.8115.61	752317 933179 979502	22879			CBOD OUT	Removal	TENIN	THE OWNER					1								
February March April May June July	21.10 26.27 31.81 15.61	933179 979502		97%				I KIN IIN	TKN OUT	Removal	NO2+NO3 IN	NO2+NO3 OUT		TN IN	TN OUT	Removal	PHOS IN	PHOS OUT	Removal	NH3 IN	NH3 OUT	Conversion
March April May June July	26.27 31.81 15.61	979502	107443		855718	34466	96%	70269	5153	93%	1085	8414		71355	13567	81%	14108	1142	92%	44842	389	99%
April May June July	31.81 15.61			88%	845355	222253	74%	78856	33194	58%	3742	9474		82598	42668	48%	9594	2222	77%	62727	17507	72%
May June July	15.61		222872	77%	792947	474219	40%	76429	76705	0%	4218	6226		80647	82931	-3%	10337	8486	18%	53719	55523	-3%
June July		991076	213147	78%	783579	438293	44%	93362	83603	10%	5858	8035		99220	91638	8%	12117	7593	37%	50499	54151	-7%
July		880544	113222	87%	767599	354471	54%	92502	76537	17%	269	605		92771	77142	17%	10702	5982	44%	48722	54524	-12%
	14.44	605418	76448	87%	582426	243430	58%	71448	65217	9%	446	468		71894	65686	9%	10633	4316	59%	37908	46158	-22%
August	10.63	474987	53904	89%	570837	262842	54%	80037	74067	7%	148	172		80186	74240	7%	9795	6089	38%	40815	57650	-41%
	10.87	662809	32613	95%	611359	66290	89%	86575	14864	83%	255	7589		86830	22453	74%	10592	2482	77%	46973	9134	81%
September	15.23	720472	28095	96%	659432	49463	92%	86123	6247	93%	826	4076		86949	10323	88%	13629	1196	91%	51845	1166	98%
October	11.96	689451	11411	98%	765897	27532	96%	89336	5287	94%	352	7428		89687	12715	86%	13719	1137	92%	53830	2295	96%
November	14.63	765387	18863	98%	869401	38319	96%	93343	4639	95%	446	4639		93789	10423	89%	12483	709	94%	50376	612	99%
December	18.48	945889	42217	96%	939985	65979	93%	89469	6908	92%	1845	10151		102834	18071	82%	19469	1078	94%	49652	1279	97%
Average	17.08	783419	78593	91%	753711	189796	74%	83979	37702	54%	1624	5606		86563	43488	49%	12265	3536	68%	49326	25032	46%
Minimum	10.63	474987	11411	77%	570837	27532	40%	70269	4639	0%	148	172		71355	10323	-3%	9594	709	18%	37908	389	-41%
Maximum	31.81	991076	222872	98%	939985	474219	96%	93362	83603	95%	5858	10151		102834	91638	89%	19469	8486	94%	62727	57650	99%
Total LBs IN/Out		9401031	943,114		9044535	2277557		1007749	452421		19490	67277		1038760	521857		147178	42432		591908	300388	
LBs Removed		8457917			6766978			555328			-47787			516903			104746			291520		
	Total	LBS	LBS	%	LBS	LBS	%	LBS	LBS	%	LBS	LBS		LBS	LBS	%	LBS	LBS	%	LBS	LBS	%
2023	Flow	TSS IN	TSS OUT	Removal	CBOD IN	CBOD OUT	Removal	TKN IN	TKN OUT	Removal	NO2+NO3 IN	NO2+NO3 OUT		TN IN	TN OUT	Removal	PHOS IN	PHOS OUT	Removal	NH3 IN	NH3 OUT	Conversion
January	21.29	827915	63036	92%	905659	78128	91%	94919	10050	89%	2193	9780		97111	19831	80%	16720	2173	87%	51915	1383	97%
February	17.08	749718	27372	96%	784221	39095	95%	88621	6141	93%	1342	8603		89963	14744	84%	20109	1267	94%	51222	1160	98%
	20.76	970905	28555	97%	936779	49575	95%	98641	7549	92%	2575	13079		101216	20628	80%	14873	1614	89%	54279	738	99%
	16.88	763238	22619	97%	829703	40640	95%	88596	6951	92%	761	5843		89358	12795	86%	11662	1851	84%	50375	542	99%
-	18.46	811094	24661	97%	863962	44309	95%	91824	6262	93%	2020	10611		93844	16873	82%	13931	2173	84%	50760	555	99%
	13.19	687305	13281	98%	650166	24616	96%	67468	5438	92%	228	6136		67696	11577	83%	10310	1648	84%	50712	703	99%
	16.20	699650	16536	98%	619230	23771	96%	62623	4928	92%	734	10488		63357	15416	76%	10057	2422	76%	36765	643	98%
	16.47	723029	23711	97%	686944	30099	96%	73856	5759	92%	445	8583		74301	14342	81%	11886	2467	79%	51836	513	99%
	15.92	633166	25545	96%	616519	34220	94%	82253	5902	93%	435	4194		82688	10095	88%	12169	1785	85%	50140	547	99%
	17.69	707918	28571	96%	726132	35391	95%	84797	7622	91%	1061	9597		85857	17219	80%	15295	2163	86%	52089	582	99%
	14.43	838841	24910	97%	822635	36419	96%	86525	6710	92%	322	3988		86847	10698	88%	18095	1783	90%	50801	592	99%
	24.79	798471	64887	92%	770439	68299	91%	64683	9034	86%	4347	15482		69030	24516	64%	16620	3616	78%	42832	828	98%
																•						
Average	17.76	767604	30307	96%	767699	42047	95%	82067	6862	92%	1372	8865		83439	15728	81%	14311	2080	85%	49477	732	99%
	13.19	633166	13281	92%	616519	23771	91%	62623	4928	86%	228	3988		63357	10095	64%	10057	1267	76%	36765	513	97%
	24.79	970905	64887	98%	936779	78128	96%	98641	10050	93%	4347	15482		101216	24516	88%	20109	3616	94%	54279	1383	99%
Total LBs IN/Out	24.75	9211250	363,684	5070	9212389	504562	5070	984806	82346	5570	16463	106384		1001268	188734	0070	171727	24962	5470	593726	8786	5570
LBs Removed		8847566	303,004		8707827	304302		902460	02340		-89921	100384		812534	100734		146765	24302		584940	0700	<b></b>
Lb3 Kellioved	Total	LBS	LBS	%	LBS	LBS	%	LBS	LBS	%	LBS	LBS	1	LBS	LBS	%	LBS	LBS	%	LBS	LBS	%
2024	Flow	TSS IN	TSS OUT	Removal	CBOD IN	CBOD OUT	Removal	TKN IN	TKN OUT	70 Removal		NO2+NO3 OUT	1	TN IN	TN OUT	Removal	PHOS IN	PHOS OUT	1	NH3 IN	NH3 OUT	
	26.40	795488	34386	96%	736069	66849	91%	78068	8246	89%	4434	17790	1	82502	26036	68%	14419	2160	85%	44848	882	98%
	18.72	866036	13380	98%	792747	37595	91%	77149	7084	91%	1174	11399		78323	18483	76%	15476	1198	92%	51801	660	98%
	24.33	918522	25921	98%	804365	46764	95%	80457	8945	89%	3606	21334		84063	30280	64%	15476	2081	86%	51801	909	99%
	24.33	918522 932718	25921	97%	804365	46764	94%	80457	7365	89% 91%	2027	18050	-	84063	25414	64% 69%	16937	2081	85%	51156	1065	98%
	16.12	727930		97%	721436	30314	94%		5561		2027	18050			17421	79%		1719				
	12.56	609278	18589 20819	97%	602255	30314 32145	96%	83968 79508	5183	93% 93%	183	11860		84226 79691	6458	92%	12670 12006	1/19	86% 86%	44065 38597	612 1057	99% 97%
		609278	20819	97%		32145	95%	79508	5183	93%	340	4128			9238	92% 87%	12006	1681	86%	42570	788	97%
	13.79				608775									72383								
-	18.35	804882	22815	97%	708991	28061	96%	75495	5328	93%	1126	10348	-	76621	15676	80%	14149	1163	92%	43116	668	98%
	11.16	597227	9431	98%	636066	14367	98%	77480	3827	95%	155	6954	-	77636	10781	86%	13799	1428	90%	43608	916	98%
October	9.49	614523	9292	98%	656743	12035	98%	82642	3607	96%	129	1797		82771	5403	93%	13526	1844	86%	47233	729	98%
	12.26	656294	9228	99%	694719	12619	98%	81529	4101	95%	414	7753		81944	11854	86%	17988	1286	93%	48634	510	99%
December	17.47	694953	14039	98%	657510	21769	97%	75031	4333	94%	1459	8721		76491	13054	83%	18534	804	96%	44914	729	98%
$\vdash$	10.07		10/	0771	200		0.071	705		0.5.1	4.5	40		70.555	455.55	0.511		46.5	0.571			
	16.96	741930	19104	97%	702978	31819	96%	78655	5724	93%	1275	10117	-	79930	15842	80%	14836	1642	89%	45913	794	98%
Minimum	9.49	597227	9228	96%	602255	12035	91%	72044	3607	89%	129	1275	0	72383	5403	64%	12006	804	85%	38597	510	97%
	26.40	932718	34386	99%	816054	66849	98%	83968	8945	96%	4434	21334	0	84226	30280	93%	18534	2456	96%	51801	1065	99%
Total LBs IN/Out		8903162	229,242		8435730	381833		943855	68690		15305	121409		959162	190098		178032	19702		550958	9525	<b>└──</b>
LBs Removed		8673920			8053897			875165			-106104		1	769064			158330			541433		