

Landfill 2025 Summary								
Date	Digested	Lime Stab	Solids Total		Bar screen	Grit and Screen		Grease
	Tons	Tons	Tons	Cost	Tons	Tons	Cost	Tons
January	680.33		680.33	\$28,074.50		19.14	\$861.30	
February	653.39		653.39	\$26,135.60		21.40	\$965.70	
March	736.06		736.06	\$29,442.40		21.19	\$953.55	
April	693.52		693.52	\$27,740.80		29.57	\$1,330.65	
May								
June								
July								
August								
September								
October								
November								
December								
Average	690.83		690.83	\$27,848.33		22.83	\$1,027.80	
Sub Total	2,763.30		2,763.30	\$111,393.30		91.3	\$4,111.20	
				\$40/Ton			\$45/Ton	
\$115,504.50								
Annual Cost to Date								
\$420,000 budgeted for 2025 /								
ES8130.54804								

Superintendents Summary Report for 2025																							
	FLOW	Precip	CBOD5		REM	Tot Susp Solids		REM	Settleable Solids		REM	Total Nitrogen		REM	Phosphorous		REM	Ammonia		CON	TKN		REM
	MGD	Inches	In	out	%	In	out	%	In	out	%	In	out	%	In	out	%	In	out		In	out	
	AVG		Limit			Limit			Limit			Limit			Limit			Monitor			Monitor		
			18 mg/L			20 mg/L			0.3 mL/L			6.0 mg/L			1.0 mg/L			1800 lbs./Day			11000 lbs/Day		
Jan	14.56	1.06	200	8	96%	193	4.6	98%	11.90	0.10	99%	23.5	2.8	88%	6.44	0.220	97%	13.5	0.25	98%	23.3	1.3	94%
Feb	16.21	3.17	171	8	95%	161	3.6	98%	11.60	0.10	99%	21.8	2.9	87%	5.45	0.150	97%	12.8	0.40	97%	21.2	1.5	93%
Mar	19.99	2.08	132	9	93%	140	7.3	95%	8.60	0.10	99%	18.2	4.3	76%	2.86	0.450	84%	9.0	0.15	98%	17.5	1.8	90%
Apr	17.38	2.95	168	9	95%	174	5.9	97%	9.90	0.10	99%				2.90	0.400	87%	11.8	0.14	99%			
May																							
Jun																							
Jul																							
Aug																							
Sep																							
Oct																							
Nov																							
Dec																							
		TOT																					
Avg	17.04	9.26	168	9	95%	167	5.4	97%	10.50	0.10	99%	21.2	3.3	84%	4.41	0.305	91%	11.8	0.24	98%	20.7	1.5	92%
With 1 Data point left, Average TN mg/L/Day = 2.9																							
With 1 Data point left, Average TKN mg/L/Day = 1.5 mg/L																							
Ammonia limit equates to approx 6 mg/L monthly Avg. (Monitor Only) / TKN limit equates to 38 mg/L Monthly Avg. (Monitor Only)																							
TN limit is 6.0 mg/L From OO1 (New Limit, Was Monitor) REM = Removal %																							
The Permit for TN = Rolling 12 Month SUM, from Outfall OO1, (Was O1A) Not to Exceed 639,261 lbs.																							
Outfall OO1 includes Flow Through O1B (DN Cell Bypass) (Above 35 MGD)																							
These numbers represent Outfall from OO1																							