

Superintendents Summary Report for 2025																							
	FLOW	Precip	CBOD5		REM	Tot Susp Solids		REM	Settleable Solids		REM	Total Nitrogen		REM	Phosphorous		REM	Ammonia		CON	TKN		REM
	MGD	Inches	In	out	%	In	out	%	In	out	%	In	out	%	In	out	%	In	out		In	out	
	AVG		Limit			Limit			Limit			Limit			Limit			Monitor			Monitor		
			18 mg/L			20 mg/L			0.3 mL/L			6.0 mg/L			1.0 mg/L			1800 lbs./Day			11000 lbs/Day		
Jan	14.56	1.06	200	8	96%	193	4.6	98%	11.90	0.10	99%	23.5	2.8	88%	6.44	0.220	97%	13.5	0.25	98%	23.3	1.3	94%
Feb	16.21	3.17	171	8	95%	161	3.6	98%	11.60	0.10	99%	21.8	2.9	87%	5.45	0.150	97%	12.8	0.40	97%	21.2	1.5	93%
Mar	19.99	2.08	132	9	93%	140	7.3	95%	8.60	0.10	99%	18.2	4.3	76%	2.86	0.450	84%	9.0	0.15	98%	17.5	1.8	90%
Apr	17.38	2.95	168	9	95%	174	5.9	97%	9.90	0.10	99%	22.5	2.8	88%	2.90	0.400	86%	11.8	0.14	99%	22.2	1.6	93%
May	24.03	5.83	123	9	93%	138	9	93%	15.50	0.10	99%	16.2	2.9	82%	2.36	0.490	79%	7.5	0.20	97%	15.7	1.7	89%
Jun	16.09	2.58				171	8	95%	10.90	0.10	99%				2.57	0.604	76%	10.3	0.14	99%			
Jul																							
Aug																							
Sep																							
Oct																							
Nov																							
Dec																							
		TOT																					
Avg	18.04	17.67	159	9	94%	163	6.4	96%	11.40	0.10	99%	20.4	3.1	84%	3.76	0.386	87%	10.8	0.21	98%	20.0	1.6	92%
With 6 Data points left, Average TN mg/L/Day = 2.6																							
With 6 Data points left, Average TKN mg/L/Day = 1.7 mg/L																							
Ammonia limit equates to approx 6 mg/L monthly Avg. (Monitor Only) / TKN limit equates to 38 mg/L Monthly Avg. (Monitor Only)																							
TN limit is 6.0 mg/L From OO1 (New Limit, Was Monitor) REM = Removal %																							
The Permit for TN = Rolling 12 Month SUM, from Outfall OO1, (Was O1A) Not to Exceed 639,261 lbs.																							
Outfall OO1 includes Flow Through O1B (DN Cell Bypass) (Above 35 MGD)																							
These numbers represent Outfall from OO1																							

## Landfill 2025 Summary

Date	Digested	Lime Stab	Solids Total		Grit and Screen	
	Tons	Tons	Tons	Cost	Tons	Cost
January	680.33	0	680.33	\$28,074.50	19.14	\$861.30
February	653.39	0	653.39	\$26,135.60	21.40	\$965.70
March	736.06	0	736.06	\$29,442.40	21.19	\$953.55
April	693.52	0	693.52	\$27,740.80	29.57	\$1,330.65
May	692.32	0	692.32	\$27,692.80	26.24	\$1,180.80
June	675.12	0	675.12	\$27,004.80	18.79	\$845.55
July						
August						
September						
October						
November						
December						
Average	688.46		688.46	\$27,681.82	22.72	\$1,022.93
Sub Total	4,130.74		4,130.74	\$166,090.90	136.33	\$6,137.55
				\$40/Ton		\$45/Ton
\$172,228.45						
Annual Cost to Date						
\$420,000 budgeted for 2025 /						
ES8130.54804						